

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3240-0694:205 Page 1 of 1

CATEGORY: Duct Smoke Detector Housing/Base

LISTEE: Fire Control Instruments, 301 2nd Avenue, Waltham, MA 02451-1133
Contact: Anthony J. Shalna (781) 471-3000*

DESIGN: Models DH-60 and DH-60 (2W) duct smoke detector units. Unit consists of a plastic enclosure, optional relay and electrical components, a separately listed smoke detector, a sampling and exhaust tube. Models DH-60 and DH-60(2W) employ listee's listed Model CPD-7051 (CSFM Listing No. 7271-0694:172) or PSD-7155 (CSFM Listing No. 7272-0694:170) smoke detectors. Refer to listee's data sheet for additional detailed system description and operational considerations.

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. Suitable for use in ducts where air velocity is between 500 and 4000 ft/min.

MARKING: Listee's name, model number, rating and UL label.

APPROVAL: Listed as duct smoke detector unit for use with separately listed electrically compatible fire alarm control units to shut down blowers to prevent abnormal smoke distribution.

XLF: 3240-1076:121

*Rev. 06-11-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 21, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager